

# Energy performance certificate (EPC)

|  |               |  |
|--|---------------|--|
| 235 Belmont Road<br>BELFAST<br>BT4 2AH | Energy rating | Valid until: 22 April 2034                   |
|  | <b>D</b>      | Certificate number: 8034-9224-4300-0937-7226 |

**Property type** Semi-detached house

**Total floor area** 165 square metres

## Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | <b>A</b>      |         |           |
| 81-91 | <b>B</b>      |         |           |
| 69-80 | <b>C</b>      |         | 69 C      |
| 55-68 | <b>D</b>      | 58 D    |           |
| 39-54 | <b>E</b>      |         |           |
| 21-38 | <b>F</b>      |         |           |
| 1-20  | <b>G</b>      |         |           |

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                    | Rating    |
|----------------------|--|-----------|
| Wall                 | Solid brick, as built, no insulation (assumed) | Very poor |
| Roof                 | Pitched, 200 mm loft insulation                | Good      |
| Roof                 | Roof room(s), no insulation (assumed)          | Very poor |
| Window               | Partial double glazing                         | Poor      |
| Main heating         | Boiler and radiators, mains gas                | Good      |
| Main heating control | Programmer and room thermostat                 | Average   |
| Hot water            | From main system                               | Good      |
| Lighting             | Low energy lighting in 50% of fixed outlets    | Good      |
| Floor                | Solid, no insulation (assumed)                 | N/A       |
| Secondary heating    | None   | N/A       |

## Primary energy use

The primary energy use for this property per year is 281 kilowatt hours per square metre (kWh/m<sup>2</sup>).

▶ [About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£3,110 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £870 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Impact on the environment

This property's environmental impact rating is E. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

## Carbon emissions

|   |                               |
|---|-------------------------------|
| <b>An average household produces</b>        | 6 tonnes of CO <sub>2</sub>   |
| <b>This property produces</b>               | 8.2 tonnes of CO <sub>2</sub> |
| <b>This property's potential production</b> | 5.8 tonnes of CO <sub>2</sub> |

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Changes you could make

▶ [Do I need to follow these steps in order?](#)

## Step 1: Low energy lighting

Typical installation cost £50

Typical yearly saving £75

Potential rating after completing step 1 **58 D**

## Step 2: Heating controls (thermostatic radiator valves)

Heating controls (TRVs)

Typical installation cost £350 - £450

Typical yearly saving £131

Potential rating after completing steps 1 and 2 **60 D**

## Step 3: Room-in-roof insulation

Typical installation cost £1,500 - £2,700

Typical yearly saving £664

Potential rating after completing steps 1 to 3 **69 C**

## Step 4: Floor insulation (solid floor)

Typical installation cost £4,000 - £6,000

Typical yearly saving £86

Potential rating after completing steps 1 to 4 **70 C**

## Step 5: Internal or external wall insulation

Typical installation cost £4,000 - £14,000

Typical yearly saving £567

Potential rating after completing steps 1 to 5 **78 C**

## Step 6: Solar photovoltaic panels, 2.5 kWp

Typical installation cost £3,500 - £5,500

---

**Typical yearly saving**

£543

---

**Potential rating after completing steps 1 to 6**84 B

---

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                        |  |
|------------------------|--|
| <b>Assessor's name</b> | Patricia Best  |
| <b>Telephone</b>       | 07788108883  |
| <b>Email</b>           | <a href="mailto:patricia@bestpropertysurveys.com">patricia@bestpropertysurveys.com</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                             |  |
|-----------------------------|--|
| <b>Accreditation scheme</b> | Elmhurst Energy Systems Ltd  |
| <b>Assessor's ID</b>        | EES/004738   |
| <b>Telephone</b>            | 01455 883 250  |
| <b>Email</b>                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

### About this assessment

|                               |                         |
|-------------------------------|-------------------------|
| <b>Assessor's declaration</b> | No related party        |
| <b>Date of assessment</b>     | 23 April 2024           |
| <b>Date of certificate</b>    | 23 April 2024           |
| <b>Type of assessment</b>     | ▶ <a href="#">RdSAP</a> |

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](#)

## **OGI**

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/)